

2021 Consumer Confidence Report Data

OMRO WATERWORKS, PWS ID: 47103573

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

Dlaim ntawv tshaabzu nuav muaj lug tseemceeb heev nyob rua huv kws has txug cov dlej mej haus. Kuas ib tug paab txhais rua koj, los nrug ib tug kws paub lug thaam.

Water System Information

If you would like to know more about the information contained in this report, please contact Steven G Bilkey at (920) 685-7025.

Opportunity for input on decisions affecting your water quality

The Omro City Council meets the first and third Tuesday of each month at 7 PM in the City Hall Council Chambers

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

Source ID	Source	Depth (in feet)	Status
1	Groundwater	202	Active
2	Groundwater	285	Active
3	Groundwater		New Well Not Yet in Service

To obtain a summary of the source water assessment please contact, Steven G Bilkey at (920) 685-7025.

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Definitions

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
HAL	Health Advisory Level: The concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice.

Term	Definition
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
SMCL	Secondary drinking water standards or Secondary Maximum Contaminant Levels for contaminants that affect taste, odor, or appearance of the drinking water. The SMCLs do not represent health standards.
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the

following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

Disinfection Byproducts

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
HAA5 (ppb)	D-5	60	60	1	1		No	By-product of drinking water chlorination
TTHM (ppb)	D-5	80	0	4.9	4.9		No	By-product of drinking water chlorination

Inorganic Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
NITRATE (N03-N) (ppm)		10	10	1.80	1.30 - 1.80		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.8600	1 of 20 results were above the action level.	8/6/2020	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
LEAD (ppb)	AL=15	0	4.10	0 of 20 results were above the action level.	8/12/2020	No	Corrosion of household plumbing systems; Erosion of natural deposits

Radioactive Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
GROSS ALPHA, INCL. R & U (n/a)		n/a	n/a	6.2	6.2	5/14/2020	No	Erosion of natural deposits

Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Omro Waterworks is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Unregulated Contaminants

Unregulated contaminants are those for which the EPA (Environmental Protection Agency) has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. The EPA requires us to participate in this monitoring.

Well #1	Value	Well #2	Value	Distribution System	Value
Bromide Test #1	26.909 ug/l	Bromide Test #1	60.124 ug/l	HAA6BR	
Bromide Test #2	25.274 ug/l	Bromide Test #2	34.99 ug/l	Test #1	2.525 ug/l
Total Organic Carbon	ND	Total Organic Carbon	ND	Test #2	1.23 ug/l
Manganese Test #1	34.586 ug/l	Manganese Test #1	153.225 ug/l	Test #3	1.825 ug/l
Manganese Test #2	35.635 ug/l	Manganese Test #2	145.87 ug/l	Test #4	2.471 ug/l
Germanium	ND	Germanium	ND		
Chlorpyrifos	ND	Chlorpyrifos	ND		
Total Permethrin	ND	Total Permethrin	ND	HAA9	
Alph Hexachlorocyclohexane	ND	Alph Hexachlorocyclohexane	ND	Test #1	2.725 ug/l
Dimethipin	ND	Dimethipin	ND	Test #2	1.23 ug/l
Oxyfluorfen	ND	Oxyfluorfen	ND	Test #3	2.723 ug/l
Profenofos	ND	Profenofos	ND	Test #4	1.825 ug/l
Tebuconazole	ND	Tebuconazole	ND		
Tribufos	ND	Tribufos	ND		
Ethoprop	ND	Ethoprop	ND		
Butylated Hydroxyanisole	ND	Butylated Hydroxyanisole	ND		
O-toluidine	ND	O-toluidine	ND		
Quinoline	ND	Quinoline	ND		
1-butanol	ND	1-butanol	ND		
2-methoxyethanol	ND	2-methoxyethanol	ND		
2-propen-1-ol	ND	2-propen-1-ol	ND		
ND=Non detectable					
ug/l= Parts Per Billion					
Date sampled-3/20/2018					